






Temperatur	Temperature	
Primär	Primary	20-90° C
Sekundär	Secondary	20-55° C
p max.	p max.	6 bar

Pumpe	Pump	
U	U	230 V, 50 Hz
Q	Q	3,5 m³/h
H	H	6 mWs
P	P	3 ... 42 W
Glykol	Glycol	max. 30 vol%

Ventile	Valves	
Rücklaufventil	Return valve	kvs 2,7 m³/h
Thermostatventil	Thermostic valve	kvs 4,0 m³/h





Web: www.unidomo.de

Telefon: 04621- 30 60 89 0

Mail: info@unidomo.com

Öffnungszeiten: Mo.-Fr. 8:00-17:00 Uhr

VIESSMANN



 **Vaillant**

WOLF

 **JUNKERS**  **BOSCH**

 **remeha**

 **DAIKIN**

ROTEX
a member of DAIKIN group



Individuelle Beratung



Kostenloser Versand



Hochwertige Produkte



Komplettpakete



Über 15 Jahre Erfahrung



Markenhersteller

Thermostat

Thermostat

Termostato


Термостат

Thermostat

Valvola termostatica

Termostat

1	20° C
2	25° C
3	30° C
4	34° C
5	38° C
6	42° C
7	46° C
8	50° C
9	55° C



Befüllen

Filling


Llenado

заполнение

Remplissage

Riempimento

Napełnianie



Nach dem Spülen
Ventil öffnen

Open valve after
rinsing

Después de la
descarga abrir la
válvula

Открыть клапан
после промывки

Ouvrir la vanne après
rinçage

Aprire la valvola dopo
il rilavaggio

Otwórz zawór po
przepłukaniu

Entlüften

Venting


Ventilar

Деаэрация


Purger

Sfiatare




Odpowietrzenie




max.
1 x





Pumpe / Pump / Bomba / Hacoc / Pompe / Pompa di circolazione / Pompa



Programm	LED Light
P1/P2 = Δp variabel	green
C1/C2 = Δp constant	orange
Min-Max	blue
Error	red
Air control	white (flashing)



Rücklaufventil
Return valve
Valvula de retorno
Клапан обратной
линии
Vanne de retour
Valvola di ritorno
Zawór zwrotny



Balanceventil
Balance valve
Valvula de balance
Балансировочный
клапан
Vanne d'équilibrage
Valvola di
bilanciamento
Zawór równoważący

